



NOTES:

1. SEE DRAWINGS E-46 AND E-47 FOR POLE BONDING REQUIREMENTS.
2. 240V CIRCUIT SHOWN. 120V IS SIMILAR EXCEPT USE 1P FUSED CONNECTOR WITH ONE 10A FUSE, IN UNGROUNDED CIRCUIT CONDUCTOR, AND BOND GROUNDED CONDUCTOR TO GROUNDING CONDUCTOR.

APPROVED BY

*AWP*

DATE

3/3/92

# STREETLIGHT - UNDERGROUND BRANCH CIRCUIT CONNECTION

DEPARTMENT OF PUBLIC WORKS



DRAWING  
NO.

E-08